



Product Service

CERTIFICATE

No. Z2 126943 0001 Rev. 00

Holder of Certificate: **Power Investment Chuangu Solar Technology(Wuxi) Ltd.**

Xinou Road, Qianqiao Street
Huishan District
214153 Wuxi City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062348001-00

Valid until: 2029-06-19

Date, 2024-06-27

(Zhulin Zhang)



CERTIFICATE

No. Z2 126943 0001 Rev. 00

Model(s): 210 × 105(mm) N type HJT cell modules:
 132 cells module:
 CG210-132-xxxW (xxx=695 to 715, in steps of 5)
 120 cells module:
 CG210-120-xxxW (xxx=630 to 650, in steps of 5)
 xxx stands for rated output power at STC.

Parameters:

Safety Class:	Class II
Max. system voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China.
Construction:	Framed, with Junction box, cable and connector.

Tested according to: IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016